



To:
Mr. Rich Houle
Project/Code Development Engineer
Uponor Housing Solutions
Apple Valley, MN 55124

Date: February 29, 2008

Subject: Demilec Spray Insulation Foam

Dear Mr. Houle

Per the test results summarized by Mr. Looney of Solvay Advanced Polymers, I do not envision any problem of Uponor fittings under normal usage due to the application of Demilec polyurethane spray insulation foam.

Therefore, Demilec Polyurethane Spray Foam Insulation is approved for use with Uponor Wirsbo AquaPEX tubing and brass and EP fittings.

With Best Regards
Chandan K. Saha, PhD
Material Scientist
Engineering Product
& Systems Development Manager

Uponor, Inc.

5925 148th Street West
Apple Valley, MN 55124
USA

Tel: (800) 321-4739
Fax: (952) 891-2008
Web: www.uponor-usa.com